



NIPPON KAIJI KYOKAI

Certificate of Type Test

Certificate No.
TA18193M

MANUFACTURER: TURK PRYSMIAN KABLO VE SISTEMLERI A.S.
PRODUCT: 250V Halogen Free Control Cables
TYPE NO.: 03XPC4Z1-R(LJST-HF), 03J2XPC4Z1-R(LJST-FRHF)
TYPE TEST NO.: 14T817
PARTICULARS: Refer to the attachment sheet
STANDARDS: IEC 60092-350/360/376, IEC 60331-11/21, IEC 60332-1-2,
IEC 60332-3-22 Cat.A, IEC 60754-1/2, IEC 61034-1/2

THIS IS TO CERTIFY that the above mentioned product has been approved by the NIPPON KAIJI KYOKAI in accordance with the Society's type test requirements for electrical equipment and cables.

This certificate is valid until 11 February 2023.

Issued at Tokyo on 10 May 2018.



T. Shimada
General Manager
Machinery Department

NIPPON KAIJI KYOKAI

Attached sheet to Cert. No. TA18193M

03XPC4Z1-R(LJST-HF) / 03J2XPC4Z1-R(LJST-FRHF)

Rated Voltage:	250V
Max Rated Conductor Temperature:	90°C
Conductor:	Stranded Copper-Class 2
Insulation:	Halogen Free Cross Linked PolyEthylene (HF-XLPE)
Flame Barrier:	Glass Mica Tape (for FR type)
Tape:	Polyester or PP
Braid:	Bare Copper Braid
Sheath:	Halogen Free Thermoplastic Compound (SHF1)
Number of Core × Cross-Sectional Area [mm ²]:	1P to 37P × 0.5 to 1.5

— The End —